

金属包塑软管
PVC Coated Flexible Conduit



PM / BM CE IP66

材质：热浸镀锌钢板及特殊绝缘处理

外层：PVC(黑色抗紫外线,防老化)

产品认证：CE, IP66

颜色种类：黑色或灰色

防护等级：IP66

使用方法：先将电线穿入管内，再配合金属软管固定头即可

Material：Hot dip galvanized steel plate and special insulation treatment


Out Material:PVC(black anti-ultraviolet, anti-aging)

Product certification:CE, IP66

Color: Black or Grey

Degree of protection:IP66

Usage: Put the wire into the tube, then tie the metal hose to the head



型号 Item No.		规格 TradeSizes		内径 d Inner Diameter	外径 D Outer Diameter	弯曲半径 Bending Radius mm±10%	包装 M Packing
黑色 Black	灰色 Gray	公制 M	英制 BSP				
PM-01B	PM-01G	6	3/16"	6.0±0.3	9.2±0.5	40	30M
PM-02B	PM-02G	8	1/4"	8.0±0.3	11.8±0.5	45	30M
PM-03B	PM-03G	10	5/16"	10.0±0.3	14.5±0.5	55	30M
PM-04B	PM-04G	13	3/8"	12.5±0.3	16.8±0.5	65	30M
PM-05B	PM-05G	16	1/2"	15.5±0.3	20.2±0.5	85	30M
PM-06B	PM-06G	20	3/4"	20.0±0.3	25.0±0.5	100	30M
PM-08B	PM-08G	25	1"	25.0±0.3	30.7±0.5	120	15M
PM-10B	PM-10G	32	1 1/4"	32.0±0.3	38.6±0.5	150	15M
PM-12B	PM-12G	38	1 1/2"	38.0±1.0	44.6±1.0	180	15M
PM-16B	PM-16G	51	2"	51.0±1.0	59.0±1.0	220	15M
PM-20B	PM-20G	64	2 1/2"	64.0±1.5	73.5±1.5	310	10M
PM-24B	PM-24G	75	3"	75.0±2.0	83.5±2.0	350	10M
PM-32B	PM-32G	100	4"	100.0±3.0	109.5±3.0	410	10M
PM-36B	PM-36G	125	5"	125.00±3.0	135.5±3.0	460	5M
PM-38B	PM-38G	150	6"	150.0±4.0	160.5±4.0	500	5M





Certificate No. : BKC26052677EC

Certificate of Conformity

Applicant : **WONG ELECTRICAL&TEAK WOOD(SELANGOR)SDN.BHD.**
33,Jalan 20/14,Paramount Garden,46300 Petaling Jaya,Selangor

Manufacturer : **ZHEJIANG HONGXIANG CONNECTOR CO.,LTD**
BUILDING A, SHENHE PIONEER PARK,
XIANGYANG INDUSTRIAL ZONE, LIUSHI TOWN, YUEQING,
WENZHOU CITY, ZHEJIANG PROVINCE, CHINA

Trademark : **GIRAELICA®**

Product : **GIRAELICA PVC Coated Flexible Conduit**

Model(s) : **PM-06B, PM-01B, PM-02B, PM-03B, PM-04B, PM-05B, PM-08B, PM-10B, PM-12B, PM-16B, PM-20B, PM-24B, PM-32B, PM-36B, PM-38B, PM-01G, PM-02G, PM-03G, PM-04G, PM-05G, PM-06G, PM-08G, PM-10G, PM-12G, PM-16G, PM-20G, PM-24G, PM-32G, PM-36G, PM-38G**

Test Standard : **EN 60529:1991+A1:2000+A2:2013**

The certificate of conformity is based on an evaluation of a sample of the above mentioned products. It does not imply an assessment of the whole production. It is possible to use CE marking to demonstrate the compliance with this LVD Directive 2014/35/EU. It is only valid in connection with the test report number:BKC26052677ES.

IP66



Manager
Jun. 05, 2026

Shenzhen BKC Testing Co., Ltd.

Room103, 1/F, Huaya Building, Huaya Industrial Park, Yousong Community,
Longhua Subdistrict, Longhua District, Shenzhen, Guangdong, China

Tel: 4000-875-382 0755-84829082 E-mail: bkc@bkc-lab.com

Certificate Search: <http://www.bkc-lab.com>